

**LAVALETTE PSD RECOMMENDED SERVICE LINE
INSTALLATION SPECIFICATIONS**

1. ALL BURIED SERVICE SHOULD BE A MINIMUM OF 3/4" O.D. WITH A PRESSURE RATING OF AT LEAST 200 P.S.I.
2. ALL BURIED LINE SHOULD HAVE NO LESS THAN 24" OF DIRT COVER.
3. ALL FITTINGS SHOULD BE BRASS, COPPER, OR STAINLESS STEEL. NO GALVANIZED STEEL OR PLASTIC FITTINGS SHOULD BE USED.
4. A PRESSURE REDUCER/REGULATOR SHOULD BE INSTALLED AT THE METER, REGARDLESS OF THE PRESSURE AT THE METER.
5. ALL LINES UNDER DRIVEWAYS, PATIOS, AND CONCRETE SLABS SHOULD BE THROUGH A STEEL OR PVC CASING PIPE.
6. ALL LINES SHOULD BE INSPECTED BY A REPRESENTATIVE OF LAVALETTE P.S.D. BEFORE ANY LINES ARE COVERED WITH DIRT.

FORM #0112795