

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Exceeded Maximum Contaminant Level (MCL) for Total Trihalomethanes**

LAVALETTE PSD-ROUTE 52 NORTH DISTRICT, WV3305011

Our water system recently violated a drinking water standard. Although this is not an emergency, you as our customers have the right to know what happened, what you should do, and what we are doing to correct the situation.

We routinely monitor for the presence of drinking water contaminants. Test results for 7/1/2016 and 9/30/2016 show that our system exceeds the standard or maximum contaminant level (MCL) for Total Trihalomethanes.

The average level of Total Trihalomethanes over the last four quarters was 81.025000000µg/L at 4150 GREENBRIAR CREEK ROAD, AT THE 2" BLOWOFF LOCATED AT THE END OF THE LINE. The standard for Total Trihalomethanes is 80µg/L.

What should I do?

You do not need to use an alternative (e.g. bottled) water supply. However, if you have specific health concerns, it is recommended that you consult with your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. However, some people who drink water containing Total Trihalomethanes (TTHM's) in excess of the MCL over many years may have an increased risk of getting cancer.

What happened? What is being done?

We routinely monitor quarterly at the longest contact time location, 4150 Greenbrier Ck. Rd. The running average as stated above has exceeded the standard (MCL).

We (Lavalette Public Service District) are working together with our water supplier (Kenova Water) to keep the TTHM levels to a standard. We continue to do extensive flushing and we are currently seeking solutions to decrease these levels. We have seen a decrease this past quarter and hope that these efforts will continue to bring these levels down to within the required range. Lavalette Public Service District has and will continue to strive to put forth the needed effort to obtain compliance in this area.

For more information, please contact: **Lavalette Public Service District @ 304-525-3771**
(Office Hours: 8:00 am to 4:00 pm Mon – Fri.)

This notice is being sent to you by: **LAVALETTE PSD-ROUTE 52 NORTH DISTRICT**